



ADDENDUM NO. 2

Project Name:	Charlottesville-Albemarle Airport Baggage Handling Systems Upgrades
RS&H Project Number:	20541892008

DATE OF ISSUANCE: April 3, 2024

MODIFICATIONS TO PROJECT MANUAL		
ITEM	SPECIFICATION	DESCRIPTION OF MODIFICATION
<i>None.</i>		
1		
2		
3		

BIDDER QUESTIONS AND RESPONSES		
ITEM	BIDDER QUESTION	RESPONSE
1	After further review of responses to RFI questions 11, 12, and 16, by the design team, further clarification is needed regarding the no load test, load test and 40 hour run in time.	The load test and no load functional tests are still required. The 40 hour run in time requirement can be fulfilled via the first 40 hours of operation with live bags.
2	Clarification to prior questions about the applicability of the contract documentation in regards to AIA Form 101-2017, Construction Contract section of the project manual and the General Terms and Conditions section, and Special Provisions sections of the project manual.	AIA Form 101-2017 will be the main form of the agreement, with all requirements of the Construction Contract section, General Conditions Section, Special Provisions Section, and all other project manual sections and all drawings incorporated as part of the contract requirements.
3		
4		

ATTACHMENTS	
ITEM	DESCRIPTION
1	
2	
3	
4	
5	

April 3, 2024

END OF ADDENDUM NO. 2